LIGHTING FIXTURE SCHEDULE

MARK	DESCRIPTION	LAMPS			LENS	FINISH	MOUNTING	BASIS OF DESIGN	NOTES
		TYPE	VOLTS	WATTS					
A	1'x1' LED CANOPY LIGHT 4000K, 10,500 LM, MIN 70 CRI	LED	UNIVERSAL (120-277V)	87W	UV STABILIZED POLYCARBONATE LENS WITH SEAL, IP65 RATED, TYPE V DISTRIBUTION	FADE AND ABRASION RESISTANT POWDERCOAT BRONZE	SURFACE	STONCO BY SIGNIFY GC88-NW-G1-SM-5-8-BZ	PROVIDE ADDITIONAL SUPPORT AS NEEDED SO THAT LENS IS FLUSH WITH CEILING GRID
B	1'X1' LED CANOPY LIGHT 4000K, 1700 LM, MIN 75 CRI	LED	UNIVERSAL (120-277V)	14W	VANDAL-RESISTANT POLYCARBONATE TEXTURED OPAQUE FOR LOW GLARE FLAT LENS	POWDERCOAT BRONZE	SURFACE	RAB VANLED10NF/D10	0-10V DIMMING
C	LED EXTERIOR WALLPACK 4000K, 6200 LM, MIN 70 CRI	LED	UNIVERSAL (120-277V)	62W	MICROPRISMATIC LENS	POWDERCOAT BRONZE	WALL	RAB SLIM62N/BL	
D	LED EXTERIOR WALLPACK 4000K, 3800 LM, MIN 70 CRI	LED	UNIVERSAL (120-277V)	37W	MICROPRISMATIC LENS	POWDERCOAT BRONZE	WALL	RAB SLIM37N/BL	
G	DUAL FUNCTION EMERGENCY/NORMAL EXTERIOR WALL PACK 4000K, 3000 LM, MIN 70 CRI	LED	UNIVERSAL (120-277V)	28W	TYPE III DISTRIBUTION	BLACK	WALL	HUBBELL GEOPACK TRP1-12L-15-4K7-3-U-BL-EH	BUILT-IN BATTERY PACK WITH BATTERY HEATER INTEGRAL SELF-TEST

LIGHTING CONTROL SCHEDULE

LOCATION	LUMINARIE	ALWAYS ON	MANUAL OVERRIDE/CONTROL	SITE PHOTOCELL ON/OFF	TIME CLOCK ON/OFF	NOTES
PARKING GARAGE	TYPE A- INDICATED ALWAYS ON	X	X			
PARKING GARAGE	TYPE A		X		X	3
EXTERIOR	TYPE A		X	X	X	1,2
EXTERIOR	TYPE B		X	X	X	1,2
EXTERIOR	TYPE C		X	X	X	1,2
EXTERIOR	TYPE D		X	X	X	1,2
EXTERIOR	BOLLARDS		X	X	X	1,2
EXTERIOR	TYPE G	X	X			

NOTES:

1. FIXTURE SHALL BE CONFIGURABLE TO UTILIZE SITE PHOTOCELL, TIME CLOCK, OR BOTH.
2. FIXTURE SHALL BE CONFIGURED FOR DUSK TO DAWN OPERATION.
3. FIXTURE ON/OFF TIMES SHALL BE COORDINATED WITH LOCAL NYSIF PERSONNEL.

ENCORUS GROUP

encorus.com

STATE OF NEW YORK · THOMAS R. GILMARTIN · 085647 · LICENSED PROFESSIONAL ENGINEER

Thomas R. Gilmartin, PE

4/12/2019

Copyright 2019 - Encorus Group Engineering, P.C. all rights reserved. No part of this drawing may be reproduced or copied in any form by any means without the written permission of the engineer. Reproduction of this drawing for use in the production of shop and/or field detail drawings is expressly forbidden.

"Unauthorized alteration or addition to any plans, specifications or reports bearing a Licensed Professional Engineer's seal is a violation of Section 7209, subdivision 2, of the New York State Education Law".

CLIENT:

NYSIF

225 OAK STREET
BUFFALO, NY 14202

PROJECT:

225 OAK ST ENVELOPE REPAIRS

225 OAK STREET
BUFFALO, NY 14202

REVISIONS:

REV	DESCRIPTION	DATE	DFTR	CHKR
0	BID DOCUMENT	2019-04-12	DGA	SBV

PROJECT NUMBER:	18277
DRAFTER:	CJR
CHECKER:	JFF
ENGINEER:	TRG
DRAWING SCALE:	NTS
DRAWING SIZE:	ANSI D

DRAWING TITLE:

ELECTRICAL LIGHTING SCHEDULES

DRAWING NUMBER:

EL601