

CONSTRUCTION

EMPLOYEE HANDOUT

FIRE SAFETY

Complete sentences by choosing the correct letter from the list below.

1. Flammable and combustible materials must be...

2. Flammable and combustible materials should not be...

3. Fire extinguishers, smoke alarms and emergency lighting...

4. Fire extinguishers and exits...

5. Sprinkler heads should have...

Select the correct letter:

- a. must be inspected monthly.
- b. should never be blocked or have access restricted.
- c. a minimum of 18 inches of clearance
- d. stored close to heat and electrical sources.
- e. disposed of only in approved containers.



Answers to quiz:
1. e. disposed of only in approved containers.
2. d. stored close to heat and electrical sources.
3. a. must be inspected monthly.
4. b. should never be blocked or have restricted access
5. c. a minimum of 18 inches of clearance.



Employee _____

Date _____